Disclaimer:

The information contained in these course notes has been compiled from various sources and is believed to be reliable and to represent the best current knowledge and opinion relative to the subject. API 510 Exam Helper offers no warranty, guarantee, or representation as to its absolute correctness or sufficiency. API 510 Exam Helper has no responsibility in connection therewith; nor should it be assumed that all acceptable safety and regulatory measures are contained herein, or that other or additional information may be required under particular or exceptional circumstances.

API 510: Pressure Vessel Inspection Code: Maintenance, Inspection, Rating, Repair, and Alteration



Objectives

This software is designed to train individuals who are interested in obtaining the API 510 Pressure Vessel Inspector Certification, as well as those who are seeking a better understanding of ASME Section VIII and IX code requirements. Online tests are designed in such a way that, student can test his proficiency and understanding of the material before exam.

Lesson 1 Service Restrictions, Joint Efficiencies, and Radiography



Lesson 1 Service Restrictions, Joint Efficiencies, and Radiography

Objectives

Understand the service restrictions placed on weld joints based on service conditions.

Identify weld joints by Categories (location in vessel).

Identify welds by Types. (How made, double welded etc.).

Determine the accept/reject values for weld imperfections located using radiography.

Define the extent of radiography required by Code for a desired joint efficiency.

Find weld joint efficiency (E) by using Table UW-12.

Determine weld joint efficiencies based on RT markings.

Determine the E to be used for calculating the required thickness or allowed pressure for Seamless Shell sections and Seamless heads.

Understand the rules for using welded pipe and tubing.

ASME Section VIII

UW-2 Service Restrictions

(a) When vessels are to contain lethal substances footnote', either liquid or gaseous, all butt-welded joints shall be fully radiographed, except under the provisions of UW-2(a)(2) and UW-2(a)(3) below, and UW-11(a)(4).

When fabricated of carbon or low alloy steel, such vessels shall be postweld heat treated (Note - When a vessel is to contain fluids of such a nature that a very small amount mixed or unmixed with air is dangerous to life)

If determined as lethal:

(1) The joints of various categories (see UW-3) shall be as follows:

(a) Except under the provisions of (a)(2) or (a)(3) below, all joints of Category A shall be Type No. (1) of Table UW-12.

(b) All joints of Categories B and C shall be Type No. (1) or No. (2) of Table UW-12.

These are the only two types which are considered acceptable for radiography by Section VIII Div.1



Type 1

Double Welded butt joint or equivalent. Backing if used must be removed.



Type 2

Single welded butt joint with backing which remains in place.

UW-3 Welded Joint Category

The term "Category" as used herein defines the location of a joint in a vessel, but not type of joint.

Category A. Longitudinal welded joints within the main shell, communicating chambers, transitions in diameter, or nozzles; any welded joint within a sphere, within a formed or flat head, or within the side plates of a flat-sided vessel; circumferential welded joints connecting hemispherical heads to main shells, to transitions in diameters, to nozzles, or to communicating chambers.

Category B. Circumferential welded joints within the main shell, communicating chambers, nozzles, or transitions in diameter including joints between the transition and a cylinder at either the large or small end; circumferential welded joints connecting formed heads other than hemispherical to main shells, to transitions in diameter, to nozzles, or to communicating chambers.

Category C. Welded joints connecting flanges, Van Stone laps, tube sheets, or flat heads to main shell, to formed heads, to transitions in diameter, to nozzles, or to communicating chambers any welded joint connecting one side plate to another side plate of a flat sided vessel.

Category D. Welded joints connecting communicating chambers or nozzles to main shells, to spheres, to transitions in diameter, to heads, or to flat-sided vessels, and those joints connecting nozzles to communicating chambers (for nozzles at the small end of a transition in diameter, see Category B).

(b) When butt welded joints are required elsewhere in this Division for Category B, an angle joint connecting a transition in diameter to a cylinder shall be considered as meeting this requirement provided the angle a (see Fig. UW-3) does not exceed 30 deg.



All requirements pertaining to the butt-welded joint shall apply to the angle joint.

An Important note:

Hemispherical heads form a Category A joint between themselves and any other part, whether it is the shell, another hemispherical head, etc. Hemispherical Heads are never considered Seamless by Code rules. The Category A weld made by attaching the Hemispherical Head to shell is considered part of the Head for calculation purposes. Later on, in this lesson we begin our discussion of formed seamless Heads. The formed heads on the exam that are considered seamless are Torispherical and Ellipsoidal, Hemispherical is not seamless by Code.

UW-51

Radiographic and Radioscopic Examination of Weld Joints

a) All welded joints to be radiographed shall be examined in accordance with Article 2 of Section V except as specified below.

A complete set of radiographs and records shall be retained by the Manufacturer until the Manufacturer's Data Report has been signed by the Inspector.

The Manufacturer shall certify that personnel have been qualified and certified in accordance with their employer's written practice SNT-TC-1A shall be used as a guideline. Alternatively, the ASNT Central Certification Program (ACCP), or CP-189 may be used to fulfil the examination and demonstration requirements of SNT-TC-1A and the employer's written practice.

A written radiographic examination procedure is not required. Demonstration of density and penetrameter image requirements on production or technique radiographs shall be considered satisfactory evidence of compliance.

The requirements of T-285 of Article 2 used only a guide. Final acceptance of radiographs shall be based on the ability to see the prescribed penetrameter image and the specified hole or the designated wire of a wire penetrameter.







b) Indications shown on the radiographs of welds and characterized as imperfections are unacceptable under the following conditions and shall be repaired as provided in UW-38, and the repair radiographed to UW-51 or, at the Manufacturer, ultrasonically examined in examined in accordance with the method described in Appendix 12.

(1) any indication characterized as a crack or zone of incomplete fusion or penetration;



(2) any other elongated indication on the radiographic which has length greater than:

- $\frac{1}{4}$ in. for t up to $\frac{3}{4}$ in.
- 1/3 t for t from $\frac{34}{4}$ in. to 2-1/4 in

1/3 t for t from 3/4 in. to 2-1/4 in.

where

t = the thickness of the weld excluding any allowable reinforcement.



For a butt weld joining two members having different thicknesses at the weld, t is the thinner of these two thicknesses. Since the value of t must be the lesser thickness this decreases the size of the maximum acceptable indication.

t = 1/2" t = 3/4"

t is the thinner member

(3) any group of aligned indications that have an aggregate (total) length greater than tin a length of 12t,

Example: t = 1" total length (L) cannot exceed 1" in 12"

Also, individual lengths cannot exceed the following:

(b) 1 1/3t fort from 3/4 in. to 2-1/4 in. * In this example none of the individual indications can exceed $1/3 \times 1^{"} = 1/3^{"} (0.333^{"})$



(3) except when the distance between the successive imperfections except 6L where L is the length of the longest imperfection in the group; This means that if the two group are isolated from each other, they can be evaluated separately with a length of 12t.

Longest Imperfection .250" D Distance must exceed 6L

L = .250" 6L = 6 x .250 = 1.5"D must be greater than 1.5" to consider the Imperfections separately

(4) rounded indications in excess of that specified by the acceptance standards gives in Appendix 4.

Example for Appendix 4: More on this during the Section V Coverage.

				•
· · · · · · · · · · · · · · · · · · ·	· · · · ·)		•	

(b) Isolated Indication [See Note (2)]

UW-52

Spot Examinations of Weld Joints

(b) Minimum Extent of Spot Radiographic Examination

(1) One spot shall be examined on each vessel for each 50 ft increment of weld or fraction thereof for which a joint efficiency from column (b) of Table UW-12 is selected. However, for identical vessels, each with less than 50 ft of weld for which a joint efficiency from column (b) of Table UW-12 is selected, 50 ft increments of weld may be represented by one spot examination.

* The idea of this rule is that each 50' increment is to be a hold point for approval; the next increment is not to be started until the previous one has been accepted. The drawing below is the simplest case; you will not see this often.



*This rule also addresses smaller, often machine welded vessels such as small air receivers. One is picked at random for spot radiography. If it passes, all are approved.

18' fraction



(2) For each increment of weld to be examined, a sufficient number of spot radiographs shall be taken to examine the welding of each welder or welding operator. Under conditions where two or more welders or welding operators make weld layers in a joint, or on the two sides of a double-welded butt joint, one spot may represent the work of all welders or welding operators.

* Every welder in a given 50' increment must have his work radiographed. It can be a individual photo (radiograph) or a group picture. Here welder A was radiographed alone, and B & C's work was examined on the same radiograph.



(3) Each spot examination shall be made as soon as practicable. The location of the spot shall be chosen by the Inspector, except that when the Inspector cannot be present or otherwise make the selection, the fabricator may exercise his own judgment in selecting the spots.

(4) Radiographs required at specific locations to satisfy the rules of other paragraphs, such as UW-9(d), UW-11 (a)(5)(b), and UW-14(b), shall not be used to satisfy the requirements for spot radiography.

Note: UW-11(a)(5)(b), will be covered in depth later in subsequent menu.

UW-9(d)

(d) Except when the longitudinal joints are radiographed 4in. each side of each circumferential welded intersection, vessels made up of two or more courses shall

have the centres of the welded longitudinal joints of adjacent courses staggered or separated by a distance of at least five times the thickness of the thicker plate.

*Longitudinal Welds Aligned must be radiographed for at least 4 inches on each side of the joint.



UW-14(b) Single openings meeting the requirements given in UG-36(c)(3) may be located in head-to-shell or Category B or C butt welded butt welded joints, provided the weld meets the radiographic requirements in UW-51 for a length equal to three times the diameter of the opening with the centre of the whole at mid-length. Defects that are completely removed in cutting the whole shall not be considered in judging the acceptability of the weld. **UW-51, not 52 to grade film.



Summary

The special radiography requirements given in UW-9 (d), UW-11 (a)(5)(b) and UW-14 (b) cannot be substituted for any of the spot radiography required by UW-52.

*We will see why this is significant when we commence our studies of "Joint Efficiencies" later.

UW-52

Spot Examinations of Weld Joints

(c) Standards for Spot Radiographic Examination.

Spot examination by radiography shall be made in accordance with the technique prescribed in UW-51(a). *The minimum length of spot radiograph shall be 6 in.*

(c)(3) Rounded indications are not a factor in the acceptability of welds that are not required to be fully radiographed.

(d) Evaluations and Retests

When a spot, radiographed as required in (b)(1) or (b)(2) above has been examined and the radiograph discloses welding which does not comply. The locations shall be determined by the Inspector, if the two additional pass, repair the failed spot, if either of the two additional spots fail the entire rejected weld shall be removed and the joint re-welded or the entire Increment completely radiographed and all defects corrected.



...., if either of the two additional spots fail the entire rejected weld shall be removed and the joint rewelded or the entire Increment completely radiographed, and all defects corrected.



UW-11

Radiographic and Ultrasonic Examinations of Weld Joints

Full Radiography. The following welded joints shall be examined radiographically for their full length

.

(1) all butt welds in the shell and heads of vessels used to contain lethal substances [see UW-2(a)];

* Remember, UW-2(a) demands that in lethal service the welds be of Type 1 for Category A and must be of either Type1 or 2 for Categories B and C.



Full Radiography. The following welded joints shall be examined radiographically for their full length.

(2) all butt welds in vessels in which the nominal thickness [see (g) below] at the welded joint exceeds 1-1/2 in. (38mm), or exceeds the lesser thicknesses prescribed in UCS-57. This paragraph is on the examination.

(b) For radiographic and ultrasonic examination of butt welds, the definition of nominal thickness at the welded joint under consideration shall be the nominal thickness of the thinner of the two parts joined. Nominal thickness is defined in 3-2.

(c) *nominal thickness* - For plate material, the nominal thickness shall be, at the Manufacturer's option, either the thickness shown on the Material Test Report {or material Certificate of Compliance [UG-93(a)(1)]) before forming, or the measured thickness of the plate at the joint or location under consideration.

(a) Full Radiography. The following welded joints shall be examined radiographically for their full length

(2) all butt welds in vessels in which the nominal thickness [see (g) below] at the welded joint exceeds 1-1/2 in. (38 mm), or exceeds the lesser thicknesses prescribed in UCS-57, UNF-57, UHA-33, UCL-35, or UCL-36 for the materials covered therein, or as otherwise prescribed in UHT-57, ULW-51, ULW-52(d), ULW-54, or ULT-57; however, except as required by UHT-57(a), Categories B and C butt welds in nozzles and communicating chambers that neither exceed NPS10 nor 1-1/8 in. (29 mm) wall thickness do not require any radiographic examination;

* If none of the rules in the paragraphs above apply then use the default thickness of 1-1/2".

This means;

If the material of construction is not one of those referenced UW-1 I (a)(2) then the default value for the thinner thickness exceeded becomes 1-1/2". Since the API 510 examination is restricted to UCS materials (carbon and low alloy steels) this rule will be demonstrated using a Carbon Steel that is classified as a P-Number 1.

UCS-57

From paragraph UCS-57:

In addition to the requirements of UW-11, complete radiographic examination is required for each butt welded joint at which the thinner of the plate or vessel wall thicknesses at the welded joint exceeds the thickness limit above which full radiography is required in Table UCS-57

THICKNESS ABOV EXAMINATION		
P-No. & Gr. No. Classification of Material	Nominal Thickness Above Which Butt Welded Joints Shall Be Fully Radiographed, in. (mm)	
1 Gr. 1, 2, 3 3 Gr. 1, 2, 3	1 ² / ₄ (32)	
4 Gr. 1, 2, 5 4 Gr. 1, 2 54 5B Gr. 1	2/4 (19) 2/6 (16) 0 (0)	
9A Gr. 1 9B Gr. 1	% (16) % (16)	
10A Gr. 1 10B Gr. 2	2/4 (19) 2/4 (16)	
10C Gr. 1 10F Gr. 6	⁵ ∕ ₈ (16) ³ ∕ ₄ (19)	

Further Explained: For P No. 1 materials the thinner of the two must exceed 1.25". Therefore, the girth weld at the 1.25 to 1.5" joint and all above it are exempt.



UW-11 Continued

(3) all butt welds in the shell and heads of unfired steam boilers. Steam Boilers are NOT on the Exam.

(4) all butt welds in nozzles, communicating chambers, etc., attached to vessel sections or heads

that are required to be fully radiographed under (1) or (3) above; however, Categories B and C butt welds in nozzles and communicating chambers that **neither exceed NPS 10 (DNS 250) nor 1-1/8 in. (29mm) wall thickness do not require any radiographic examination;

** This only applies to circumferential welds in small (NPS 10 / 1-1/8" thick.) nozzles and chambers. Longitudinal seams are not exempted by this rule.



Now for the hardest rule to understand!

(5) all Category A and D butt welds in vessel sections and heads where the design of the joint or part is based on a joint efficiency permitted by UW-12(a), in which case:

Category A and B welds connecting the vessel sections or heads shall be of Type No. (1) or Type No. (2) of Table UW-12; * Just means they must be radiographable.

Category B or C butt welds [but not including those in nozzles or communicating chambers except as required in (2) above] which intersect the Category A butt welds in vessel sections or heads or connect seamless vessel sections or heads shall, as a minimum, meet the requirements for spot radiography in accordance with UW-52.



* This paragraph is only mandatory when it is desired by the designer to use the highest joint efficiency possible for calculations of thickness require or pressure allowed.

It is a choice the designer makes when there are no mandatory requirements based on service or material as found in UW-11 (a) (1) *Lethal Service, (2) *Thickness exceeded

all butt welds joined by... electro-gas welding is not on the exam.

ultrasonic examination in accordance with UW- 53 may be substituted for radiography for the final closure seam of a pressure vessel if the construction of the vessel does not permit interpretable radiographs in accordance with Code requirements. The absence of suitable radiographic equipment shall not be justification for such substitution.

exemptions from radiographic examination for certain welds in nozzles and communicating chambers as described in (2), (4), and (5) above take precedence over the radiographic requirements of Subsection C of this Division.

Note: This moans that oven though P-No. 5 for example requires RT in all thicknesses the small/thin nozzles re exempt.

Spot Radiography. Except as required in (a)(5)(b) above, butt welded joints made in accordance with Type No. (1) or (2) of Table UW-12 which are not required to be fully radiographed by (a) above, may be examined by spot radiography. Spot radiography shall be in accordance with UW-52.

* If full RT is not mandatory Spot Radiography is done because the designers chose it.

If spot radiography is specified for the entire vessel, radiographic examination *is not* required of

Category B and C butt welds in nozzles and communicating chambers that exceed neither NPS

10 nor 1-1/8 in. wall thickness

No Radiography. Except as required in (a) above, no radiographic examination of welded joints is required when the vessel or vessel part is designed for external pressure only, or when the joint design complies with UW-12(c).

* The designer can choose not to do RT if there is no mandatory requirement such as lethal, thickness, or the desire for a higher joint E.

Before starting shell and head calculations let's have a look at the types of welds and the weld joint efficiencies that apply based on the amount of radiography applied.

These E values are found on Table UW-12 of Section VIII Division 1.

The following is a simplification for the API 510 Exam; it does not reflect all of the possible combinations of radiography, weld types and the resulting joint efficiencies

UW-12

Joint Efficiencies

Table UW-12 gives the joint efficiencies E to be used in the formulas of this Division for joints completed by an arc or gas welding process. Except as required by UW-11(a)(5), a joint efficiency depends only on the type of joint and on the degree of examination of the joint and does not depend on the degree of examination of any other joint.

(a) value of E not greater than that given in column (a)* of Table UW-12 shall be used in the design calculations for fully radiographed butt joints [seeUW-11(a)], except that when the requirements of UW-11(a)(5) are not met, a value of E not greater than that given in column (b) of Table UW-12 shall be used. * Known as Full Radiography

So now we are sent back to UW-11(a)(5)

UW-11(a)(5) all Category A and D butt welds in vessel sections and heads where the design of the joint or part is based on a joint efficiency permitted by UW -12(a), in which case:

(a) Category A and B welds connecting the vessel sections or heads shall be of Type No. (1) or Type No. (2) of Table UW-12; * (simply means it can be radiographed)

(b) Category B or C butt welds [but not including those in nozzles or communicating chambers except as required in (2) above *(excludes small/thin nozzles)] which intersect the Category A butt welds in vessel sections or heads or connect seamless vessel sections or heads shall, as a minimum, meet the requirements for spot radiography in accordance with UW-52.

UW-11(a)(5) explained: This rule is pointed toward Code manufacturers who buy parts from other "Code Shops' and basically assemble a vessel. The concern is as follows;

Code Shop A buys a rolled and welded shell from Code Shop B, Shop B fully radiographs the Type 1 weld and the shell part will be delivered to Shop A with a joint E of 1.0. which is essentially equal to a seamless shell.

Code Shop A welds on two seamless formed heads. Unless Shop A performs at least Spot RT on the Category B welds connecting the heads to the shell there will have been no radiographic testing of Code Shop As welders. A graphical representation follows.

Example 1: The longitudinal seam weld is of Type 1. It has received Full RT at Code Shop B. Shop A has not performed the required Spot RT on the head to shell welds.



UW-11(a)(5) So this means that Shop A cannot simply weld the heads, nozzles etc. and never do any radiographic testing of the Shop A welders. To make things consistent this rule applies even if the entire vessel is made by one Code Shop.

So no matter what the circumstances this Spot RT must be performed to take a joint efficiency from Col. A of to Table UW-12 for seamed shell course. Example 3: One last comment. On the shop floor these two shells both have the potential for a Joint E of 1.0. You will see this again in UW-12(d) Seamless Shells and Heads.

Seamless Shell Course

Seamed Shell Course Type 1 Full RT

(d) A value of E not greater than that given in *column (b) of Table UW-12 shall be used in the design calculations for spot radiographed butt-welded joints [see UW-11(b)].

* Known as Spot Radiography

(e) A value of E not greater than that given in * column (c) of Table UW-12 shall be used in the design calculations for welded joints that are neither fully radiographed nor spot radiographed [see UW-11(c)]. * No Radiography

Now let's examine the first three Types listed on Table UW-12 and examine the joint types, the amount of radiography and the resulting Joint Efficiencies.



Table UW-12 Maximum Allowable Joint Efficiencies for Arc and Gas Welded Joints

					Degree of Radiographic Examination		
Type No	. Ioint Description	Limitations		Ioint Category	(a) Full [Note (1)]	(b) Spot	(c) None
(1)	Butt joints as attained by double-welding or by other means which will obtain the same quality of deposited weld metal on the inside and outside weld surfaces to agree with the requirements of UW-35. Welds using metal backing strips which remain in place are excluded.	y None e		A, B, C & D	1.00	0.85	0.70
(2)	Single-welded butt joint with backing strip other than those included under (1)	 (a) None except as in (b) below (b)Circumferential butt joints with one plate of UW-13(b)(4) and Figure UW-13.1, sketch (i) 	offset; see)	A, B, C & D A, B & C	0.90 0.90	0.80 0.80	0.65 0.65
(3) T	Single-welded butt joint without use of backing strip	g Circumferential butt joints only, not over $\frac{5}{6}$ in thick and not over 24 in. (600 mm) outside	n. (16 mm) diameter	A, B & C	NA	NA	0.60
			Full	Spot	Non	e	
	ype 1-Cat. A,B,C,&D E	Butt Joints as attained by	Col. A	Col. B	Col.	C	
	c	louble-welding or by other means which will	Full RT	Spot RT	No F	RT.	
		obtain the same quality on the inside and outside. Backing strip if used must be removed after welding s completed.	E = 1.0	E = .85	E = .	70	
7	Type 2-Cat. A, B, C, &D	ingle-welded butt joint vith backing strip which emains in place after velding is completed. imitations apply see table IW-12.	E = .90	E = .80	E = .	65	
				7			

UG-116

Joint Efficiencies based on RT Marking

Next, we will discuss Nameplate RT markings and how to determine the joint E to be used in the thickness or pressure calculations to follow. These RT markings and their descriptions are found in paragraph UG-

116. We will now discuss these accompanied by graphical representations.

"RT 1" when all pressure retaining butt welds, other than B and C associated with nozzles and communicating chambers that neither exceed NPS 10 nor 1-1/8 inch thickness have been radiographically examined for their full length in a manner prescribed in UW 51, full radiography of the above exempted Category B and C butt welds if performed, may be recorded.



"RT 2" Complete vessel satisfies UW-11(a)(5) and UW- 11(a)(5)(b) has been applied. The spot RT rules of UW-52 must be applied to the spot RT and the Full RT rules of UW-51 to the long seams. So, the 50' increments apply and all welders in that increment must be examined by radiography.



"RT 2" Complete vessel satisfies UW-11(a)(5) and UW- 11(a)(5)(b) has been applied. This is the second Case of RT 2 resulting in E = 1.0, again the rules of UW-52 apply.



"RT 3" Complete vessel satisfies spot radiography of UW-11(b). The simplest example, one welding operator and only three radiographs in 122' of weld. The following assumes Type 1 welds for all weld seams.



"RT 4" When only part of the vessel satisfies any of the above. * Only part of the vessel has been radiographed due to a thickness limit being exceeded as listed in UCS 57 or the desire to use E = 1.0.



The next consideration is the shells and heads of vessels which are considered seamless. The Efficiencies used to calculate these vessel parts are not found on Table UW-12 but are instead listed in paragraph UW-12(d).

Seamless vessel sections or heads shall be considered equivalent to welded parts of the same geometry in which all Category A welds are Type No. 1. For calculations involving circumferential stress in seamless vessel sections or for thickness of seamless heads, E=1.0 when the spot radiography requirements of UW-11(a)(5)(b) are met. E=0.85 when the spot radiography requirements of UW-11(a)(5)(b) are not met, or when the Category A or B welds connecting seamless vessel sections or heads are Type No. 3, 4, 5, or 6 of Table UW-12.

* Note this rule applies to the Code Shop A and B issue.



Seamless vessel sections or heads shall be considered equivalent to welded parts of the same geometry in which all Category A welds are Type No. 1. For calculations involving circumferential stress in seamless vessel sections or for thickness of seamless heads, E=1.0 when the spot radiography requirements of UW-11(a)(5)(b) are met.



Seamless vessel, E= 0.85 when the spot radiography requirements of UW-11(a)(5)(b) are not met, or when the Category A or B welds connecting seamless vessel sections or heads are Type No. 3, 4, 5, or 6 of Table UW-12.

*Weld Type 3 to 6 cannot be radiographed by Code rules.



Welded pipe or tubing shall be treated in the same manner as seamless, but with allowable tensile stress taken from the welded product values of the stress tables, and the requirements of UW-12(d) applied.



UW-12 Joint Efficiencies

For the purposes of choosing joint efficiencies when doing vessel section or head calculations on the API 510 Examination the following can be said.

RT 1

Full Use 1.0 if joints are of Type 1 or 0.90 if Type 2

RT 2 Case 1: Use 1.0 with Seamless Heads and Shells Case 2: Seamed Shells/Seamless Heads Shells Use 1.0 if joints are Type I or if Type 2 Use 0.90 Use 1.0 for seamless heads RT 3

Use 0.85 if Joints are of Type 1 or 0.80 if of Type 2 Use 0.85 for Seamless heads RT 4

* Special case of selective radiography * Use Table UW-12 based on Joint Type and RT described in the exam question

No RT

Go to Table UW-12 and look up the E to be used for the type of weld under consideration.

Case1: Type 1 Use 0.70

Case 2: Type 2 Use 0.65

Seamless heads use 0.85

Remember that there only two (2) joint efficiencies possible for Seamless Shell and Seamless Heads they are;

or 0.85

1.0 When the rules of UW-11(a)(5)(b) have been applied (UW-52 Spot RT applied).

0.85 When the rules have not been applied (UW-52 Spot RT not applied).

DO NOT GO TO TABLE UW-12 FOR THE E TO USE IN SEAMLESS HEADS OR SEAMLESS SHELLS.

